

FULL VIEW

DOOR COMPANY



SECTION 08360

1. GENERAL

1.1. SECTION INCLUDES

- A. Overhead folding doors.
- B. REDD™

1.2. RELATED SECTIONS

- A. Section 03300 - Cast-In-Place Concrete: Prepared opening in concrete. Execution requirements for placement of anchors in concrete wall construction.
- B. Section 04810 - Unit Masonry Assemblies: Prepared opening in masonry. Execution requirements for placement of anchors in masonry wall construction.
- C. Section 05500 - Metal Fabrications: Steel frame and supports.
- D. Section 06114 - Wood Blocking and Curbing: Rough wood framing and blocking for door opening.
- E. Section 07900 - Joint Sealers: Perimeter sealant and backup materials.
- F. Section 08710 - Door Hardware: Cylinder locks.
- G. Section 16050 - Basic Electrical Materials and Methods: Installation and requirements for electrical connections.
- H. Section 16130 - Raceway and Boxes: Empty conduit from control station to door operator.
- I. Section 16150 - Wiring Connections: Electrical service to door operator.
- J. National Electric Manufacturers Association (NEMA): NEMA ICS 4 - Industrial Control and Systems: Enclosures.

1.3. REFERENCES

- A. AS1170.2:2002 - Structural Design Actions - General Principles.
- B. AS4100-1990- SAA Steel Structures Code.
- C. AS 1288 - Glass in Buildings - Selection and Installation.
- D. AA-6063-T6 - Standards for Aluminum Alloy and Temper.
- E. ASTM A513, Type 1 - Steel Tubes.

- F. ASTM A1008 – Sheet Steel for Covers.
- G. ASTM A36 – Steel Bars.
- H. ASTM A36 – Sheet Steel for Tracks/Channels.

1.4. PERFORMANCE REQUIREMENTS

- A. Wind Loads: Design and size components to withstand loads caused by pressure and suction of wind acting normal to plane of wall as calculated in accordance with applicable code.
 - 1. Design pressure of _____ lb/sq ft (_____ kPa).
 - 2. Maximum deflection of 1/300 of opening width.
- B. Single-Source Responsibility: Provide doors, tracks, motors, and accessories from one manufacturer for each type of door. Provide secondary components from source acceptable to manufacturer of primary components.

1.5. SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.
- C. Shop Drawings: Indicate plans and elevations including opening dimensions and required tolerances, accessories and anchors, jamb details, connection details, anchorage spacing, hardware locations, and installation details.
- D. Selection Samples: For each finish product specified, two complete sets of color chips representing manufacturer's full range of available colors and patterns.
- E. Verification Samples: For each finish product specified, two samples, minimum size 6 inches (150 mm) square, representing actual product, color, and patterns.
- F. Manufacturer's Certificates: Certify products meet or exceed specified requirements.
- G. Operation and Maintenance Data.
- H. Submit written agreement in manufacturer's standard form signed by manufacturer and installer agreeing to repair or replace defective doors that are warped, twisted, bowed or damaged as a result of defective product.

1.6. QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section with minimum five years documented experience.
- B. Installer Qualifications: Authorized representative of the manufacturer with minimum five years documented experience.
- C. Products Requiring Electrical Connection: Listed and classified by Underwriters Laboratories, Inc. acceptable to authority having jurisdiction as suitable for purpose specified.
- D. REDD™ Motor System shall be warranted against manufacturing defects for a period of 2 years.

1.7. DELIVERY, STORAGE, AND HANDLING

- A. Delivery: Deliver materials to site in manufacturer's original, unopened containers and packaging, with labels clearly indicating manufacturer, material, and location of installation.
- B. Storage: Store materials in a dry area indoor and protected from damage and in accordance with manufacturer's instructions.
- C. Handling: Handle and lift all items carefully during installation to prevent damage and protect finishes.

1.8. PROJECT CONDITIONS

- A. Pre-Installation Conference: Convene a pre-installation conference just prior to commencement of field operations, to establish procedures to maintain optimum working conditions and to coordinate this work with related and adjacent work.
- B. Environmental Conditions: Prior to and during installation, environmental conditions shall be in accordance with door manufacturers latest published recommendations for temperature, rain, wind, humidity, ventilation, and illumination.

1.9. WARRANTY

- A. Manufacturer warrants to the original purchaser within two years from date of installation, if a product sold under this warranty proves to be defective in material or workmanship through normal use and service according to maintenance and operations instructions, as verified by inspection by persons authorized by Full View Door Company, Full View Door Company will replace or repair (at Full View Door Company option) the defective product.

- B. Manufacturer warrants the steel frame against rust, in painted non-damaged condition for a period of two years from original purchase. This warranty does not apply to scratched, dented, damaged or corroded areas of the frame.

2. PRODUCTS

2.1. MANUFACTURERS

- A. Full View Door Company; www.fullviewdoorcompany.com 1
121 Main St.
Sacramento, CA 95838

- B. Substitutions: Not Permitted

2.2. FOLDING OVERHEAD DOORS

- A. Bi-Fold Doors: Vertically gliding door with no floor tracks.
 - 1. Approved Product: Sovereign Bi-Fold
 - 2. Curtain: Constructed from 2-1/2 inch by 1-1/2 inch (65 mm by 40 mm) top and side rails and 1-1/4 inch by 1-1/2 inch (32 mm by 40 mm) mid rails.
- B. Panels: Panels shall be secured by glazing bead, santoprene or PVC wedges.
 - 1. Panel Heights: As indicated on Drawings.
 - 2. Panel Heights: Even division of the open height equaling _____rows, not to exceed 24 inches per panel height.
- C. Brackets and Tracks: Mono section configuration.
- D. Side Guides: 5-1/2 inch by 2-3/8 inch (140 mm by 60 mm) extruded aluminum sections with twin 1/8 inch (3 mm) tracks.
- E. Hardware/Hinges: Cast stainless steel constructed hinges with teflon inserts to ensure quiet and low friction operation.
- F. Operation: Door shall be balanced by the use of torsion springs connected to a rotating shaft. The shaft ends are attached to cable drums which lift/lower the curtain via a flexible cable.
 - 1. Electrical.
- G. Size:
 - 1. Height: _____feet (_____ meters).
 - 2. Width: _____feet (_____ meters)

- H. Locking:
 - 1. Centrally mounted, two way mortise key lock.

2.3. FINISHES

- A. Finish, Ferrous Metals: All surfaces except working machine parts shall receive the following factory applied finish:
 - 1. Powder coating.
 - 2. Abrasive clean to SSP-SP6
- B. Finish, Aluminum: Provide the following factory applied finish:
 - 1. Clear anodized aluminum.
 - 2. Abrasive clean to SSP-SP6
 - 3. Powder coating.
- C. Finish, Color:
 - 1. As designated in Door Schedule
 - 2. As selected from manufacturer's full range of available colors.
 - 3. Custom color.
 - 4. Manufacturer/Color:_____.

2.5. MOTORS** NOTE TO SPECIFIER ** Retain one of the following two paragraphs. Delete this Article if no motorized doors. Coordinate with Division 11 for control systems and Division 16 for electrical work.

- A. Model: REDD™, 1HP AC motor with 39:1 gear ration gearbox direct mounted to 1” door drive shaft. Motor is provided with control panel (mounted separately) and is controlled by a touch screen control station, photo eyes, and hardware necessary for installation of motor and control panel.
 - 1. Primary Speed Reduction: Worm gear-in-oil-bath reducer. Gear ratio is 39:1 with shaft speed of 34 RPM.
 - 2. Motor Travel: Motor up and down travel is set digitally in the control panel and door position is established by integrated shaft position encoder.
 - 3. Control Station: Touch screen control station provided as standard and is capable of being mounted into single gang electrical box (not provided by Full View Door Company). Minimum dimensions of the electrical box are 3”x2”x2 1/2” and the box shall be square corner welded construction.

4. Primary Entrapment Device: NEMA 4 Monitored Photo Sensors mounted maximum of 6 inches above the finished floor at each side of the door opening interior.
 5. Secondary Entrapment Device: REDD ALERT™ obstruction sensing technology. Door controls shall monitor the door operation for obstruction during the close cycle. If amperage increases above set limit, the motor shall stop and reverse direction. The sensitivity is set by a qualified installer during initial commissioning and shall be checked and adjusted annually.
- B. Temperature Rating: -15°F to 125°F
1. 100% duty cycle. Unlimited number of operations per hour.
- C. Construction:
1. Frame: 18.52" x 4.31" x 8.425"
 2. Frame Color: RAL 9005 Black
 3. Gearbox Oil Type: CLP VG680 Mineral Oil
 4. Bearings: Sealed Bearings - pre lubricated from factory
 5. Mounting: M4 - Vertical Orientation or M3 Horizontal Orientation.
 6. Power Requirements: 110 volt AC, Single Phase, 6 amps.
- D. Accessories
1. Universal Radio Receiver: Manufactured by Liftmaster™ model 850 LM.
 - a. Capable of 310 Mhz, 315 Mhz, or 390 Mhz radio transmitters with Security + 2.0 Remotes
 - b. Direct wires into REDD™ control panel. Power and controls are administered by REDD™ Control panel.
- E. Quality Control
1. Factory Tests:
 - a. Cycle each REDD™ motor head and gearbox before packaging to insure proper operation.
 - b. Bench test each touch screen control panel prior to packaging for proper operation and configuration.

3. EXECUTION

- A. Notify Architect in writing of deviations from manufacturer's recommended installation tolerances and conditions. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result under the project conditions. Commencement of installation constitutes acceptance of conditions.
- B. Complete installation and wiring in accordance with Full View Door Company installation manual for REDD motor system. Ensure proper orientation for motor system in accordance with written

3.1. EXAMINATION instructions.

- A. Do not begin installation until openings have been properly prepared.
- B. Verify wall openings are ready to receive work and opening dimensions and tolerances are within specified limits.
- C. Verify electric power is available and of correct characteristics.
- D. If preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.2. PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.3. INSTALLATION

- A. Inserts and Anchorages: Furnish inserts and anchoring devices suitable for the installation of the units and consistent with the manufacturer's installation requirements. Coordinate delivery with other work to avoid delay.
- B. Install overhead doors, operating equipment, hardware, seals, stops, anchors, inserts, supports and track in accordance with approved shop drawings and the manufacturer's printed instructions.
- C. Coordinate installation with adjacent work to ensure proper clearances and allow for maintenance.
- D. Anchor assembly to wall construction and building framing without distortion or stress.
- E. Securely brace door tracks suspended from structure. Secure tracks to structural members only.
- F. Fit and align door assembly including hardware.

- G. Coordinate installation of electrical service. Complete power and control wiring from disconnect to unit components.
- H. Install in accordance with manufacturer's instructions and in proper relationship with adjacent construction. Test for proper operation and adjust until satisfactory results are obtained.
Demonstrate operation to owner's personnel.

3.4. CLEANING AND ADJUSTING

- A. Lubricate, test and adjust door assembly to smooth operation free from warp twist or distortion and in full contact with weatherstripping.
- B. Clean doors, frames and glass.
- C. Remove temporary labels and visible markings.

3.5. PROTECTION

- A. Do not permit construction traffic through overhead door openings after adjustment and cleaning.
- B. Protect installed products until completion of project.
- C. Touch-up damaged coatings and finishes and repair minor damage before Substantial Completion.

3.6. MAINTENANCE

- A. Post Installation Maintenance:
 - 1. Contractor and installer shall provide Owner with complete company name, address phone number, fax number and assigned contact for emergency repairs and scheduled maintenance for the installed door(s).
- B. Training/Instruction for Owner for Operation and System Maintenance:
 - 1. Manufacturer shall instruct Owner's representative in regular tenant provided maintenance and operation of installed doors.

END OF SECTION